

For Abhaya Education

Secretary

Principal  
**ABHAYA SCHOOL**  
(Affiliated to CBSE Code No: 3630083)  
Gundla Pochampally, Kompally  
Hyderabad-500100



**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From  
The District fire officer,  
Kukatpally Division.

To,  
Narendar,  
Abhaya School,  
Sy.No: 402,  
405,  
406,  
Gundlapochampally,  
Quthbullapur Mandal,  
Medchal District,

Ack. No.384670002021 Dated:27/05/2021

Sir,  
Sub: **TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Kukatpally Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of Abhaya School, Abhaya School, Sy.No: 402, 405, 406, Gundlapochampally, Quthbullapur Mandal, Medchal District/- Gundlapochampally/Medchal/Medchal , – Regarding.**



Ref: 1. Acknowledgement No 384670002021  
2. This Office NOC for Occupancy Ack/RC No.131/DFO/NZ/2013 dt.27/05/2021  
3. Non Multi storeyed Building Inspection Committee Report,  
Ack. No. 384670002021, dt. 27/05/2021

\*\*\*\*\*

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of Abhaya School, Abhaya School, Sy.No: 402, 405, 406, Gundlapochampally, Quthbullapur Mandal, Medchal District/-Gundlapochampally/Medchal/Medchal
- 2) The above said building was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with 1 Ground, 2 Floors, with a height of 10.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with 1 Ground, 2 Floors, with a height of 10.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	6.00	6.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	1.00	6
2	Entry Gate Head Clearance	1.00	5
3	Exit Gate Width	1.00	6
4	Exit Gate Head Clearance	1.00	5.00

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point ( Most Remote Point) With in a storey or a mezzanine floor to the door	1.00	15.00

2	to an Exit. The Dead end of the corridor length in exit access (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	1.00	5.00
---	--	------	------

## 6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.80	1	Ground	Terrace
2	External staircases	1.80	1	Ground	Terrace

## 7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	586.27	EDUCATIONAL B-1 Schools up to senior secondary level	147.00	2.93	3.60
2	1st Floor	772.56	EDUCATIONAL B-1 Schools up to senior secondary level	193.00	1.93	3.60
3	2nd Floor	269.18	EDUCATIONAL B-1 Schools up to senior secondary level	67.00	1.35	3.60

## 8) Fire Shaft as per Occupancy NOC:

## 9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	3.00	1.00	0.00	0.00	0.00
2	1st Floor	4.00	1.00	0.00	0.00	0.00
3	2nd Floor	2.00	1.00	0.00	0.00	0.00

## 10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	1	17
First Aid Hose Reel	1	3
Wet Riser	1	0
Down Comer	1	1
Yard Hydrant	1	0
Automatic Sprinkler System	1	0
Manually Operated Electronic Fire Alarm Systems	1	1
Automatic Detection and Alarm System	1	0
Under-ground Static Water Storage Tank Combined Capacity for Wet Riser, Yard Hydrant and Sprinklers per Set of Pumps in Litres	1	0
Terrace Tank over Respective Tower Terrace in Litres	1	25000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm <sup>2</sup>	1	450
Number of Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm <sup>2</sup> at Remotest Location ( Electrical)	1	0
Capacity of Electrical Pump in LPM	1	0
Number of Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm <sup>2</sup> at Remotest Location ( Diesel)	1	0
Capacity of Diesel Pump in LPM		0
Number of Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm <sup>2</sup> at Remotest Location ( Electrical/Jockey)	1	0
Capacity of Electrical (Jockey) Pump in LPM	1	0

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

**12. Remarks :**

As per the inspection report the renewal of Noc is approved

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Abhaya School, Abhaya School, Sy.No: 402, 405, 406, Gundlapochampally, Quthbullapur Mandal, Medchal District/- Gundlapochampally/Medchal/Medchal** with a height of **10.00 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison - A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,  
District fire officer,  
Kukatpally Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

For Abhaya Educational Society

*[Handwritten Signature]*

Secretary

*[Handwritten Signature]*  
Principal  
**ABHAYA SCHOOL**  
(Affiliated to CBSE Code No: 3630083)  
Gundla Pochampally, Kompally.  
Hyderabad-500100